

## Elimination of Harmonic Contents in a Cascaded Multilevel Inverter using Adaptive Hybrid Technique

M.Sravya<sup>\*A</sup> and M.Seshu<sup>A</sup>

<sup>A</sup>Department of EEE, PVPSIT, Vijayawada, AP, India

Accepted 05 November 2013, Available online 01 December 2013, Vol.3, No.5 (December 2013)

### Abstract

The non-linear loads generate serious harmonic currents and reactive power to the distribution and transmission System, which results in a low power factor, leads to voltage notch and reduces the utilization of the distribution system. Uninterruptible power supply plays a major role in today's commercial world which avoids the loss occurring due to the power failure. Among the appliances, inverter is one of the essential components that perform DC-AC conversion. In this paper, a hybrid technique is proposed to eliminate the harmonics ideally. The technique utilizes fuzzy logic and artificial neural network in the optimal selection of switching angles. A hybrid evaluation technique evaluates the obtained optimal switching angles that are attained from the fuzzy inference system as well as neural network. The proposed technique is tested with a three level H-bridge inverter and the resultant fundamental and harmonics voltage are analyzed. The results reveal the effectiveness of the technique in eliminating the harmonics that are generated from the inverter.

**Keywords:** Harmonics, Fuzzy logic, Neural Network, Switching angles, Multilevel inverter.

### 1. Introduction

Uninterruptible Power Supply (UPS) systems are extensively used for supplying emergency power to crucial loads that cannot take up utility failure. Irrespective of variations in the input source or load condition, maintaining a constant voltage and constant frequency supply for critical loads, is the major function of an UPS. UPS supplies the needed uninterruptible AC power to linear and nonlinear loads. Critical equipments, such as computers, automated process controllers, and hospital instruments have widespread application for UPS, which serves as emergency power source. Diode rectifier, Pulse Width Modulation (PWM) inverter, input/output filter, DC-link capacitor, battery charger and battery, battery on/off switch, and load transformer are the major components of this system. For the DC-AC conversion, a full-bridge PWM inverter is employed. A filter is used to obtain the sinusoidal waveform from the PWM inverted pulse waveform.


UPS devices may degrade the power quality by creating harmonic currents although they are economical, flexible and energy efficient. Harmonics are undesirable sinusoidal voltages or currents present in power systems that have frequencies which are integer multiples of the frequencies of the supply system. By polluting the input supply of sensitive equipment harmonics introduced by

nonlinear loads, can cause faulty operation of the connected equipments. Current is drawn in a non-sinusoidal manner by the nonlinear loads that are connected to the sinusoidal supply voltage. Harmonic current source and Harmonic voltage source are the two types harmonic sources into which nonlinear loads can be categorized. The source side as well as the load side can generate both types of harmonics. The harmonics contained in voltage supply usually generate the current harmonic and it depends on the type of the load for example resistive load, capacitive load, and inductive load. Harmonics causes malfunctioning of electrical/electronic parts, overheating of neutral wires, transformer heating, and malfunctioning of power factor correction capacitors, power generation and transmission losses, disruption of protection, control and communication networks as well as customer loads.

### 2. Proposed Method

The proposed adaptive technique reduces the harmonics by combining the fuzzy logic and the neural network. This technique can eliminate harmonics selectively by optimally and adaptively choosing the switching angles of the UPS inverter. By selecting optimal switching angles, harmonics generation can be avoided in inverters that are used in UPS devices. Consider that the UPS utilizes a multi-level inverter with  $l$   $N$  levels and  $N$ CH-bridge converters. The inverter model is depicted in Fig 1.

\*Corresponding author: M.Sravya



**Fig 1:** Proposed Inverter model

The mathematical model of the inverter output voltage can be represented as,

$$V_h = \frac{4V_{dc}}{h\pi} \sum_{j=0}^{N_t-1} (-1)^j \cos(h \alpha_j)$$

where,  $V_{dc}$  is the input DC voltage and  $\alpha_j$  is the switching angle for the H-bridge and  $V_h$  is the voltage of the  $h^{th}$  order harmonic that is generated by the inverter. The hybrid technique, which selectively eliminates the odd harmonics, is detailed in the following sub-sections.

**2.1 Fuzzy Rules Based on Switching Angles**

In the hybrid technique, fuzzy logic plays a fundamental role in training the neural network according to the switching angles and the harmonics generated by them. In the first stage of the technique, the fuzzy rules are generated based on the switching angles, which are in the range  $(0, \pi/2)$ . The regular switching angle range is divided into different interims and a fuzzified switching angle pattern is generated. The switching angle interims are determined using the following relation,

$$I_k = ((k - 1)\Delta I, k\Delta I); 1 \leq k \leq N_I$$

where,  $N_I$  is the total number of intervals in the range  $(0, \pi/2)$ ,  $(k - 1)\Delta I$  and  $k\Delta I$  are the minimum range and maximum range of the  $k^{th}$  term, respectively, i.e.  $I(k) = [D_{min}, D_{max}]$ . Here,  $\Delta I$  is the interim range and it can be determined as,

$$\Delta I = \frac{(\frac{\pi}{2}) - 0}{N_I}$$

After fuzzification, a dataset is obtained with fuzzy variables. For every  $k^{th}$  fuzzy class, there are  $r$   $N$  patterns of

switching angles and the corresponding inverter output voltages. The frequency of each voltage pattern present in the RHS of each of the  $k^{th}$  fuzzy class is determined. The voltage pattern in ever  $k^{th}$  class that has the maximum frequency is selected as the output pattern of the class and hence the dataset is re-structured as follows,

The re-structured fuzzified dataset  $DF$  is used to train the fuzzy inference system (FIS). Once the training process is completed, the FIS is ready for use and obtains the output voltage status, for any given switching angle.

**2.2 Hybrid Evaluation of Switching Angles**

The proposed technique performs a hybrid evaluation to determine the optimal switching angles, which can reduce the generation of harmonics in the UPS inverter. To perform this, we utilize an iterative approach, which initiates arbitrary search and concludes with optimal switching angles after  $g$   $N$  iterations. The entire technique considers the requirement of eliminating the harmonics generation by selectively mitigating any of the harmonics. In other words, the technique can mitigate the selected harmonics and so the entire harmonics generation. When a harmonic is to be strictly mitigated,  $SAYH : [1, H, H, N]$ , then it must be indirectly given as input to the technique. Accordingly, the technique determines the voltage pattern that has minimum  $H$ th order harmonics voltage. For instance, if the 5th order and 7th order harmonics are to be strictly mitigated in eliminating the harmonics generation, the harmonic voltage 5 V and 7 V should be very small. From the data set the switching angle pattern corresponding to the selected harmonic voltage patterns is determined. To perform the selective mitigation, the selection factors have to be given as input. Then, iterative approach is initiated with the generation of switching angles in their intervals. In the approach, a pool of arbitrary vectors are generated as follows

$$Z_a = [\alpha_0^{(a)} \alpha_1^{(a)} \dots \dots \alpha_{N_I-1}^{(a)}]; \quad 0 \leq a \leq P_{size} - 1$$

where,  $Z_a$  is the  $a^{th}$  vector present in the pool and  $\alpha_j^{(a)}$  is the  $j$ th switching angle of  $a^{th}$  vector. Every vector in the pool needs to satisfy the constraint,

$$\alpha_0^{(a)} < \alpha_1^{(a)} < \dots < \alpha_{N_I-1}^{(a)}$$

The generated vector is evaluated by inputting vector to the trained FIS and the neural network. From the obtained output vectors, the evaluation factor is determined as follows

$$E_f^{(a)} = 0.3 [\beta_1 THD_a^{net} + \beta_2 THD_a^{FIS} + (THD_a^{net} - THD_a^{FIS})^2]$$

where,  $E_f^{(a)}$  is the evaluation factor for every arbitrary vector,  $THD_a^{net}$  and  $THD_a^{FIS}$  are the total harmonic distortion, when the  $a^{th}$  vector is the switching angle pattern estimated by the neural network and FIS, respectively and  $\beta_1$  and  $\beta_2$  are constants. The THD can be determined as follows


$$THD_a^{net} = \frac{1}{|V_{out_1}^{(a)}|} \sqrt{\sum_{H=3,5..}^{N_H} \sigma_H |V_H^{(a)}|^2}$$

where,  $V_{out_1}^{(a)}$  and  $V_H^{(a)}$  are the fundamental voltage estimated by the neural network for the  $a^{th}$  vector and the  $h^{th}$  order harmonics voltage respectively and  $\sigma_H$  is the selection factor for  $h^{th}$  order harmonics. From the pool,  $P_{size}/2$  vectors that have minimum evaluation factor are selected and subjected to vector replacement. In the vector replacement operation, the vector that has the least evaluation factor is obtained. Based on the vector, the replacement of elements of the remaining vector are performed as follows

$$\alpha_j^{new} = \begin{cases} \frac{\alpha_j^2 + 1}{\alpha_j} ; \alpha_j < \alpha_j^{least} \\ \alpha_j ; \alpha_j = \alpha_j^{least} \\ \frac{\alpha_j^2 - 1}{\alpha_j} ; \alpha_j > \alpha_j^{least} \end{cases}$$

where,  $\alpha_j^{new}$  is the  $j^{th}$  new switching angle and  $\alpha_j^{least}$  is the  $j^{th}$  switching angle, which is obtained from the vector that has the least evaluation factor. Thus obtained new vectors are subjected to satisfy the constraint given in above equation. Once the vector elements replacement is done,  $P_{size}/2$  vectors are obtained. They are placed in the pool along with the selected  $P_{size}/2$  vectors so as to make the pool size to be  $P_{size}$ . The entire process is repeated until the number of iterations reaches  $I_{max}$ . Once the maximum number of iterations is reached, the process is terminated and the vector which has the least evaluation factor is obtained from the pool. The resultant vector has the optimal switching angles that can prevent the generation of harmonics for the given UPS inverter, by selectively mitigating the given harmonic elements.


**3.Implementation Results**




(i)

The implementation of the proposed technique is performed in the working platform of MATLAB (version 7.10) and we have utilized the provided fuzzy and neural network toolboxes. In the evaluation phase, we have considered that the UPS has the inverter type of H-bridge inverter, which is responsible for generating the harmonics affected voltage waveforms. The inverter has 3 H-bridges

and so 3 switching angles  $\alpha_0, \alpha_1$  and  $\alpha_2$  are need to be selected optimally. The technique is implemented in such a way that it can eliminate the 3<sup>rd</sup> order and 5<sup>th</sup> order harmonics and so it can minimize the total harmonic distortion. During the generation of fuzzy rules,  $N_1 = 5$  is considered and accordingly the rules are generated for the corresponding  $N_1 = 5$  classes. Once the fuzzy rules have been generated, the network training process has also been performed. The performance of the network in its training stage is depicted in Fig.2. In the hybrid evaluation of switching angles, the iterative approach is tested for different number of iterations. The output voltage obtained for those attained optimal switching angles are given in output waveforms.



(ii)



(iii)

**Fig2:**The performance of the neural network training process in the proposed technique

**4. Results and Discussion**

The implementation of the proposed technique is performed in the working platform of MATLAB (version 7.10) and we have utilized the provided fuzzy and neural network toolboxes. In the evaluation phase, we have

considered that the UPS has the inverter type of H-bridge inverter, which is responsible for generating the harmonics affected voltage waveforms. The inverter has 3 H-bridges and so 3 switching angles  $\alpha_0, \alpha_1$  and  $\alpha_2$  are need to be selected optimally. The technique is implemented in such a way that it can eliminate the 3<sup>rd</sup> order and 5<sup>th</sup> order harmonics and so it can minimize the total harmonic distortion. During the generation of fuzzy rules,  $N_1 = 5$  is considered and accordingly the rules are generated for the corresponding  $N_1 = 5$  classes. Once the fuzzy rules have been generated, the network training process has also been performed. In the hybrid evaluation of switching angles, the iterative approach is tested for different number of iterations. The output voltage obtained for those attained optimal switching angles are given in output waveforms.




Fig3. Matlab simulation Circuit




Fig4: Final output waveform from the inverter




Fig5: Output waveform switching angles of inverter bridge1




Fig6: Output waveform switching angles of inverter bridge2




Fig7: Output waveform switching angles of inverter bridge3

**Conclusions**

In this project, a hybrid technique has been proposed to eliminate the harmonics that are generated from the UPS’s multilevel inverters. The technique was implemented to evaluate its performance in the elimination of harmonics in a 7-level 3 H-bridge inverter. The performance was evaluated in different iteration levels of the hybrid evaluation technique. From the results, it has been shown that the proposed technique can reach a remarkable level in harmonics elimination by mitigating the dominant odd order harmonics. The results analysis has shown that the suggested optimal switching angles can avoid the generation of harmonics and so the generated voltage waveform can maintain its harmonics free shape. By using the obtained switching angles, the harmonics generation can be avoided and so the subjected UPS can offer uninterruptible power supply with very less risk factors to the utilities.

**References**

Kai Zhang, Yong Kang, JianXiong and Jian Chen (May 2003), Direct Repetitive Control of SPWM Inverter for UPS Purpose, *IEEE Transactions on Power Electronics*, Vol. 18, No. 3, pp.784-792.  
 Praveen K. Jain, Senior Member, Jose R. Espinoza and Hua Jin (Sept 1998), Performance of a Single-Stage UPS System for Single-Phase Trapezoidal-Shaped AC-Voltage Supplies, *IEEE Transactions on Power Electronics*, Vol.13, No.5, pp.912-923.

- S.A.Z. Murad, M.N.Md. Isa and N.A. Rahman (2007), Monitoring System for Uninterruptible Power Supply, *American Journal of Applied Sciences*, Vol.4, No.3, pp.181-183.
- Yuedong Zhan, Jianguo Zhu, YouguangGuo and Hua Wang (Oct 2007), Development of a Single-phase. High Frequency UPS with Backup PEM Fuel Cell and Battery, *Proceeding of InternationalConference on Electrical Machines and Systems*, Seoul, Korea, pp.1840-1844.
- Ming Tsung Tsai and Chia Hung Liu (July 2003), Design and Implementation of a Cost-Effective QuasiLine-Interactive UPS with Novel Topology, *IEEE Transactions on Power Electronics*, Vol.18, No.4, pp.1002-1011.
- C. Liu, B. Wu, N. Zargari, D. Xu and J. Wang (June 2009), Novel Nine-Switch PWM Rectifier-InverterTopology. For Three-Phase UPS Applications, *EPE Journal*, Vol.19, No.2, pp.1-9.
- K.Chandrasekaran, P.AVengkatachalam, Mohd Noh Karsiti and K.S.RamaRao (2009), Mitigation of Power Quality Disturbances, *Journal of Theoretical and Applied Information Technology*, Vol.8, No.2, pp.105-116.
- K.R.Valluvan and A.M.Natarajan (Dec 2008), Implementation of ADALINE Algorithm on a FPGA forComputation of Total Harmonic Distortion of load current, *ACSE Journal*, Vol.8, Issue II,pp.35-41.
- R.Senthil Kumar, Jovitha Jerome and S.NithyaBhama (April 2011), Analysis of Three Phase Four WireInverter for UPS Fed Unbalanced Star Connected Load, *International Journal of Computer and Network Security*, Vol. 2, No. 4, pp.104-110.
- A.Kargarian and A.R. Seifi (May 2010), A Compound Compensation Using DFACTS and Switch BasedFault Current Limiter (SFCL), *The Pacific Journal of Science and Technology*, Vol.11, No.1,pp.120-128.
- T.Mahalakshmi (July 2010), Current Harmonic Compensation and Power Factor Improvement by Hybrid Shunt Active Power Filter, *International Journal of Computer Applications*, Vol. 4, No.3, pp.9-13,
- Selective Elimination of Harmonic Contents in an UPS using Novel Adaptive Hybrid Technique, 114
- Ying-Yu Tzou, Rong-ShyangOu, Shih-Liang Jung and Meng-Yueh Chang (July 1997), High- Performance. Programmable AC Power Source with Low Harmonic Distortion Using DSP-Based Repetitive Control Technique, *IEEE Transactions on Power Electronics*, Vol.12, No.4, pp.715-725.
- Xiao Sun, Martin H. L. Chow, Frank H. F. Leung, DehongXu, Yousheng Wang and Yim-Shu Lee (May 2002), Analogue Implementation of a Neural Network Controller for UPS Inverter Applications, *IEEE Transactions on Power Electronics*, Vol.17, No.3, pp.305-313.
- O.Bouhali, M.Berkouk, B.Francois, C.Saudemont, S.Labioud (2005), Solving Harmonics Elimination. Problem in Three-Phase Voltage controlled Inverter using Artificial Neural Networks, *Journalof Electrical Systems*, Vol.1, No.1, pp.39-51.